

Distribution Network Reconfiguration Based on Particle Clonal Genetic Algorithm

Yemei Qin

Swan College, Central South University of Forestry and Technology, Changsha, 410004, China
 School of Information Science and Engineering, Central South University, Changsha, 410083, China
 E-mail: qinyemei@yeah.net

Ji Wang*

School of Information Science and Engineering, Central South University, Changsha, 410083 China
 E-mail: wangji@mail.csu.edu.cn

Abstract—Distribution network reconfiguration is an important aspect of automation and optimization of distribution network system. To handle massive binary code infeasible solutions in distribution network reconfiguration, a kind of sequence code is presented in which a loop is a gene and the label of each switch in the loop is the gene value. To solve mutation probability and slow the convergence of clonal genetic algorithm (CGA) in the later stage, in this paper particle clonal genetic algorithm (PCGA) is proposed, in which we build particle swarm algorithm (PSO) mutation operator. PCGA avoids the premature convergence of PSO and the blindness of CGA. It ensures evolution direction and range based on historical records and swarm records. The global optimal solution can be obtained with fewer generations and shorter searching time. Compared with CGA and clonal genetic simulated annealing algorithm (CGSA), IEEE33 and IEEE69 examples show that PCGA can cut the calculation time and promote the search efficiency obviously.

Index Terms—sequence code, distribution network reconfiguration, infeasible solution, PCGA

I. INTRODUCTION

Distribution network system is an important part of power system which connects power produce with consumers. Distribution network reconfiguration is an important aspect of automation and optimization of the distribution network system. The aim of distribution network reconfiguration is that it can bring big economy and society benefits for enhancing system's security and reliability by changing the open/close status of the connection and section switches under normal or abnormal operations.

Closed loop construction and opened loop running are the distribution network's characteristic. Distribution network configuration is to bring down the network loss and isolate the fault point and balance the voltage through adjusting the combination status of connection

switches and section switches. Therefore, it is an important way of economic running and reliability of power network.

Recently methods for solving this problem tend to newborn bionic optimizations, such as genetic algorithm (GA), ant swarm algorithm (AA), particle swarm algorithm (PSO), immune algorithm (IA), etc. GA is the most widely applied method among them. The binary-coded GA with mature theory and simple operation is still used largely. However, the calculation precision of this kind of coding isn't high when it is used to optimize functions, and "combination explosion" is brought about when it is used to optimize combinations. Some scholars improved coding scheme and adopted integer code [1] or real code [2], which enhanced efficiency. But the radial running construction (without loops and without isolate nodes) of distribution network may originate massive infeasible solutions using the different codes as above. This paper gives a loop sequence code method, which can preclude infeasible solutions in the process of configuration.

Based on PSO and CGA principles, this paper puts forward a new algorithm - particle clonal genetic algorithm. This algorithm constructs a new mutation operator - PSO mutation operator, which replaces gene mutation operator of CGA. Based on historical individual and swarm records, PSO mutation operator adjusts the evolution direction and range. These operations can avoid the blindness of CGA mutation, and reduce the probability of devious mutation and enhance the velocity of evolution.

II. PARTICLE CLONAL GENETIC ALGORITHM

A. Building PCGA

PCGA is obtained by blending PSO with CGA according to their advantages and shortages, and their advantages and shortages are as the following.

- (1) Both of them can be coded with binary, real or sequence.
- (2) CGA doesn't converge prematurely. But when

*Corresponding author

mutation probability is too small, it is very difficult to find the new individual, and when it is too large, the blindness and random of search turn worse.

PSO converges quickly and requires few experience parameters. The influence of swarm scale is very slight and system behavior is hardly weakened when the number of individual is decreased. But its main shortcoming is premature convergence.

(3) CGA individuals are chosen for the optimal solution through competition, and the whole swarm evenly moves toward the best zone.

PSO seeks for the optimal solution through cooperation instead of competition. Swarm optimal solution sends information to other particles indirectly, and each particle doesn't share information directly.

(4) CGA individuals aren't capable of memory and each only reflects its present status. Their evolution ranges and directions can't be controlled.

PSO individuals (particles) are capable of memory. They can control their evolution ranges and directions based on historical information and present status. Normally, particle can converge to the optimal solution quickly.

(5) CGA operation is indirect and random. Consequently, some newborn individuals are eliminated because of low adaptive degree.

PSO is direct and can automatically adjust optimization ranges and directions based on individual historical optimal solution and swarm historical optimal solution. So the blindness of evolution is avoided.

As a result, PCGA, combining PSO with CGA, can develop respective merits, and compensate opponent defects, and make the process of searching optimal solution efficiency.

B. PCGA operator

There are three operators according to sequence code.

a. CGA Selection Operator

Roulette means, named as adaptive-degree proportion means too, is adopted. It is the most elementary and popular selecting method. The basic idea is that the selection probability of each individual is proportional to adaptive-degree. In this method the chromosome chooses its offspring by the probability. If N is the size of the swarm, F_i is the adaptive-degree of individual i , the selected probability of individual i is written as

$$P_{si} = F_i / \sum_{j=1}^N F_j \tag{1}$$

b. CGA shift operator

It shifts one or more genes which are selected randomly forward or backward in turn. It can be classified into two basic types: single shift operator and multi-shift operator.

c. PSO mutation operator

From elementary PSO formula, this paper builds a PSO mutation operator, which decides mutation direction and range on the basis of particle and swarm historical

optimal solution and the evolution velocity of particle.

Let $x_{\max,i}$ be the code of historical optimal solution $F_{\max,i}$ of particle i , and X_{\max} be the code of swarm historical optimal solution F_{\max} , and $\Delta x_{\max,i}$ be the velocity. Then $\Delta x_{\max,i}$ of the No. t is given as the following [3]

$$\Delta x_{\max,i}^t = [\sum_{k=2}^t (x_{\max,i}^k - x_{\max,i}^{k-1})] / t \tag{2}$$

PSO mutation operator is

$$\begin{cases} \Delta x_{\max,i}^{t+1} = \omega \Delta x_{\max,i}^t + c_1 r_1 (x_{\max,i} - x_i^t) + c_2 r_2 (X_{\max} - x_i^t) \\ x_i^{t+1} = x_i^t + \Delta x_{\max,i}^{t+1} \end{cases} \tag{3}$$

where ω is the inertia factor, c_1 and c_2 are the weight factors, r_1 and r_2 are random real numbers from 0 to 1.

PSO mutation operator is made up of two parts: one is to predict change range and direction, the other is to execute mutation manipulation concretely. Therefore, PSO mutation operation has the self-study ability, and the prediction before mutation makes that this operation is not a simple random mutation but a mutation with enhancing individual adaptive ability to the environment.

III. DISTRIBUTION NETWORK RECONFIGURATION

A. Reconfiguration frame graph

Figure 1 shows the system structure of distribution network reconfiguration. It is mainly made up of PCGA model block and several preparation models.

Reconfiguration should put emphasis on coding and eliminating infeasible solutions and PCGA operators.




Figure 1 The system structure

B. Chromosome coding

Coding scheme is the main factor influencing the efficiency of the intellectual optimal algorithm. Distribution network reconfiguration using binary code may generate massive infeasible solutions. So this paper gives a sequence code rule. Compared with binary code, this code is realized easily and the probability of effective codes is high.

Each loop of power network is coded with nature number and all switches of each loop are coded singly

(from 1 to the number which is the number of switches of this loop) [4]. This code regards each loop as gene, and the opened switch's label in counterpart loop as gene value. This value must be positive integer number. The length of chromosome equals to the number of connection switches (the number of loops). Figure 2 is an example of 16-node distribution system. The Nos.10, 12, and 15 switches are connection switches.




Figure2. IEEE16 distribution system after coding

The loop formed by the No.10 switch (including the Nos.9, 7, 4, and 10 switches) is defined as the first loop. Table I clearly shows that the right-hand switch of the connection switch is coded as the No.1 switch and the connection switch itself is the last number in the loop. So the length of chromosome in this distribution system is three. If connection switches in Figure 2 are all opened and other switches are closed, its code is (4 3 5). The code rule covers all switch-combination states, and there are no infeasible solutions, which meets the request of one-to-one mapping between chromosomes and solutions. For the system in Figure 2, there are 60 solutions using the new rule, but according to binary rule, there are 2^{12} solutions whose proportion of infeasible solutions is 98.535% and the majority of calculation is ineffective.

Table I . Switches coding

loop \ encode	1	2	3	4	5
NO.1	9	7	4	10	
NO.2	11	8	12		
NO.3	14	13	5	6	15

The code rule above is very convenient for single loop. But for complex distribution system, in which there are common switches between loops, the rule must be researched further. Some infeasible solutions occur after genetic operations because of common switches. Though multi-loop is few, it exists. Reference [5] expounds it clearly. The conclusion is that single loop is a system without common switches among loops; double loop is a system in which there are common parts between every two loops while not common parts every three loops; the loop, in which there are common switches among three or more loops or between any two loops, is defined as multi-loop.

C. Eliminating infeasible solutions

Figure 3 shows some simplified double loops. The No.1 loop consists of A(C)B, and its code of switch

A-B-(C)-A is 1,2; The No.2 loop is comprised of A(D)B, and its code of switch A-B-(D)-A is 2,1. AB is the common part and has different code in each loop, others aren't common.




Figure3. Four basic combinations of double loop
 — the path (a path may include several switches) without opened switch.
 - - - the path with opened switch




Figure4. 27 basic combinations of triple loop
 — the path(a path may include several switches) without opened switch.
 - - - the path with opened switch

There are four combinations given in Figure 3. From (1) to (4), the codes of chromosome are [2 2], [2 1], [1 1], and [1 2]. The fourth state is infeasible, because a loop is formed, which break the radial construction rule in distribution system. This state is coded as [1 2], that is, double loop has the common switch opened and does not have any other switches opened, thus a loop is brought about. Therefore, infeasible solutions only is a quarter of

all solutions, the proportion is very small. As a result, the code is valid when two connection switches are not simultaneously on the shared path of two loops.

Simplified formation of triple loop is presented in Figure 4. The No.1 loop is made up of BAOB and its code of the switch B-A-O-B is 1,2,3; OACO are components of the No.2 loop and sequence code of the switch O-A-C-O is 1,2,3; and the No.3 loop is composed of BOCB and its code of the switch B-O-C-B is 1,2,3. AO is the common switch of the No.1 and the No.2 loop, coded with 2 in the No.1 loop and with 1 in the No.2 loop, respectively; CO is the common part of the No.2 and the No.3 loop, coded with 3 in the No.2 and with 2 in the No.3 loop, respectively; and BO is the common part of the No.1 and No.3 loop, coded with 3 in the No.1 loop and with 1 in the No.3 loop, respectively.

There are 27 combinations altogether and their codes are shown in Figure 4. The Nos.8,10,11,12,16,17,19,20, 22,25,and 26 states are infeasible for a loop which breaks the radial construction rule in distribution system; or for an isolated node which destroys the connectivity rule. From these states, two regulations are found: on one hand, the common path of two loops is opened twice, thus a loop occurs; on the other hand, all the common paths of every two loops are opened simultaneously, such as the No.16 and the No.20 states, thus the isolated node O occurs. All infeasible solutions are 11/27 of all solutions. The rule of triple-loop is induced: if common path between two loops is opened twice or more, or all common paths are opened, the solution is infeasible and this chromosome should be excluded.

D. CGA shift operator

Under sequence code, CGA shift operator should be adjusted.

Table II . Shift operator

single shift operator	
4 <u>2</u> 3	$\xrightarrow[\text{time_shift=1}]{\text{point_shift=2}}$ 4 <u>1</u> 3 (left)
	4 <u>3</u> 3 (right)
Multi-shift operator	
4 <u>2</u> 3	$\xrightarrow[\text{max_shift=3}]{\text{min_shift=2}}$ 4 <u>1</u> <u>1</u> (left)
	4 <u>3</u> <u>5</u> (right)

(1) Single shift operator: Table II shows an example. The *point_shift* is a gene (a loop) selected randomly, and the *time_shift* is the number of shift. The value of *time_shift* should be less than the length of this loop. Besides, the *right_left* is a flag, which decides to shift toward the left or the right (by the clockwise or the anticlockwise) in the loop. The code after the shift is sent to a new chromosome.

(2) Multi-shift operator: an example is given in Table II. The *min_shift* and *max_shift* are two genes selected randomly, which are the beginning and the end gene position of shift operation respectively. They cannot be equal; moreover *min_shift* must be less than *max_shift*. Or, the former steps are repeated until the requirement is fulfilled. Then all other genes between *min_shift* and

max_shift are shifted by single shift operator, which can insure that every loop has only one opened branch.

E. Reconfiguration step

The operation steps of PCGA are as the following

- Step1** initialize the parameters including *swarm_size*, the length of chromosome L, the inertia factor ω , the weight factors c_1 and c_2 , and the limit velocities v_{max} and v_{min} .
- Step2** set the stopping condition q .
- Step3** yield the first swarm *initial_swarm*.
- Step4** evaluate individual adaptive degree of present swarm.
- Step5** execute CGA selection and shift operators, and come into being PSO swarm.
- Step6** search the best position of particle *pbest* and the best position of swarm *gbest*.
- Step7** execute PSO mutation operator.
- Step8** evaluate individual adaptive degree of swarm.
- Step9** judge whether to satisfy the step2 or not. If it is yes, let all calculations stop; else return to step5.

IV. EXAMPLE ANALYSIS

Using the standard IEEE33 and IEEE69 distribution systems (their structures are in appendix) as examples and the least network loss (showed in formula 4) as the objective function, the distribution network is reconfigured.


$$\min LP = \sum_{i=1}^b k_i R_i |I_i|^2 = \sum_{i=1}^b k_i R_i \frac{P_i^2 + Q_i^2}{V_i^2} \quad (4)$$

where R_i is the branch resistance, P_i and Q_i are the active power and the inactive power of branch terminal, V_i is terminal node voltage of branch, b is the number of branch, k_i is the status variable of switch i , and if k_i is 0, then switch i is open and if k_i is 1, then switch i is close, and I_i is the branch current.


Every parameter is set as: *swarm_size* is 30, ω is 0.8, both c_1 and c_2 both are 2.0, v_{max} and v_{min} are 4.0 and -4.0 respectively, q is 10(no change in the continuous 10 generations), the maximum number of iterations is 10^3 , and flow calculation precision is 10^{-6} .

Figure 5 gives the reconfiguration solutions of IEEE33 system (showed in figure 5(a)) and IEEE69 system (showed in figure 5(b)) with PCGA. In the figure, the number of iterations is X axle, and the maximum adaptive degree (MaxAdap) is Y axle. In the figure, the maximum adaptive degree (MaxAdap) and the average adaptive degree (AverAdap) of each generation are marked. From the figure, we also find the number of iterations of PCGA when the optimal solution is obtained. It is only 7 in IEEE33 and 14 in IEEE69. The convergences both are very quickly.

To analyze further the feasibility and optimization of PCGA in distribution network reconfiguration, this paper also reconfigure the IEEE33 and IEEE69 systems with improved CGA (given in reference[6]) and CGSA (given in reference [7]) separately.



(a)



(b)

Figure 5. The reconfiguration solutions of IEEE33 and IEEE69 system with PCGA


CGSA (the Clonal Genetic Simulated Annealing Algorithm), which combines CGA and SA, puts the Metropolis sample rule of the SA into the CGA, and takes this rule as the standard rule through which CGSA can decide if the search converges or not. So the generated chromosome of CGA will become more and more excellent and converge quickly. At the same time, it will not be trapped in local optimal solutions. Figure 6 shows the reconfiguration solution with CGSA, and it is worse than the solution with PCGA.

Table III and Table IV prove the feasibility of reconfiguration with PCGA. The active power loss and the node voltage quality can be improved evidently. The loss descends with 29.84% in IEEE33 and 55.34% in IEEE69, respectively, the lowest node voltage ascends


with 5.73% in IEEE33 and 3.42% in IEEE69, respectively. So PCGA is better than CGA and CGSA.

Besides, in IEEE69, several equivalent optimal results occur because nodes 44, 45, and 46 are zero load and the results of opening any one of the switch 43-44, 44-45, 45-46, and 46-47 are same. In order to have a fair comparison, references [6] and [7] showed in Table III and Table IV are manipulated by using sequence code and setting their initial conditions according to PCGA.

Besides, both CGSA and PCGA in IEEE69 system are manipulated 50 times. Figure 7 shows their number of generations when the optimal solution is obtained. Table V gives the minimum generations (MinGen), the maximum generations (MaxGen), the average generations (AverGen) and the average time (ATime).



(a)



(b)

Figure6. The reconfiguration solutions of IEEE33 and IEEE69 system with CGSA

Table III. Reconfiguration solution of IEEE33 based on PCGA

	before reconfigured	reference[7]	this paper
Open switches set	7-20,11-21,8-14, 17-32,24-28	19-20,11-21,11-12, 25-26,7-8	19-20,11-21,11-12, 25-26,7-8
Active power loss(MW)	2.0189	1.4165	1.4165
Active descendant loss degree(%)	-	29.84	29.84
Lowest node voltage(p.u.)	0.9133	0.9682	0.9656
Lowest voltage ascendant degree(%)	-	6.01	5.73
Run-time(s)	-	229.150	12.218

Table IV. Reconfiguration solution of IEEE69 based on PCGA

	before reconfigured	reference[6]	reference[7]	this paper
Open switches set	10-65,14-68,	10-65, 13-14	10-65, 13-14	10-65,13-14
	12-19,38-47,	12-19, 43-44	12-19, 45-46	12-19,44-45
	26-53	49-50	49-50	(43-44,45-46
				46-47),49-50
Active power loss(MW)	0.22606	0.10095	0.10095	0.10095
Active descendant loss degree(%)	-	55.34	55.34	55.34
Lowest node voltage(p.u.)	0.9097	0.9428	0.9415	0.9408
Lowest voltage ascendant degree(%)	-	3.64	3.49	3.42
Run-time(s)	-	586.374	397.382	25.376




Figure7. Search ability comparison between PCGA and CGSA

Table V. Statistics running 50 times

IEEE69	MinGen	MaxGen	AverGen	ATime(s)
CGSA	11	66	27.3	181.43
PCGA	6	58	19.84	25.93

As expected, PCGA has fewer generations and needs less time than CGA and CGSA, that is, the former has higher search efficiency and better search ability.

V. CONCLUSION

(1) Sequence code resolves the multi-loop problem in distribution network reconfiguration, eliminates infeasible solutions, and improve the calculation efficiency.

(2) PCGA not only combines the advantages of CGA and PSO, but also avoids premature convergence of PSO and the blindness of CGA. It can determinate itself evolution direction and range, and ensure global

convergence.

(3) Compared with CGA and CGSA, PCGA need fewer generations and less time when the global optimal solution is obtained.

(4) The standard IEEE33 and IEEE69 examples express that the method in this paper can speed up the process of evolution, and gain the global optimal solution, and enhance the search efficiency.

Appendix

The IEEE33 system and IEEE69 systems [6] and [7] are shown in Figure A and Figure B, respectively.




Figure A 33-node distribution network diagram

